



# TEST REPORT

MODEL NAME : UP100S12W2(V1)

1. DESIGN VERIFY TEST
  - 1-1. INPUT FUNCTION TEST
  - 1-2. OUTPUT FUNCTION TEST
  - 1-3. PROTECTION FUNCTION TEST
2. SAFETY TEST
3. RELIABILITY TEST

**1. DESIGN VERIFY TEST**

**1-1. INPUT FUNCTION TEST**

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
VOLTAGE RANGE	180~264VAC	I/P: testing O/P:full load Ta:25 °C	test ok	P
FREQUENCY RANGE	47~63Hz no damage osc	I/P:180~264VAC O/P:full~min. load Ta:25 °C	test ok	P
EFFICIENCY	84% typ.	I/P:220VAC O/P:full load Ta:25 °C	84.5%	P
AC CURRENT	0.78A/220VAC typ.	I/P:220VAC O/P:full load Ta:25 °C	0.8A/220VAC	P
INRUSH CURRENT	70A typ. cold start	I/P:220VAC O/P:full load Ta:25 °C	65A	P
LEAKAGE CURRENT	2.5mA max.	I/P:230VAC O/P:min. load Ta:25 °C	2.2mA	P

**1-2. OUTPUT FUNCTION TEST**

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
RIPPLE&NOISE	170mVp-p max.	I/P:220VAC O/P:full load Ta:25 °C	90mV	P
VOLTAGE ADJ. RANGE	12V ± 5%	I/P:220VAC O/P:min. load Ta:25 °C	11~13V/220VAC	P
VOLTAGE TOLERANCE	12V ± 3%	I/P:180VAC/264VAC O/P:full/min. load Ta:25 °C	± 1.16%	P
LINE REGULATION	12V ± 1%	I/P:180~264VAC O/P:full load Ta:25 °C	± 0.1%	P

<b>LOAD REGULATION</b>	12V± 2%	I/P:220VAC O/P:full-min. load Ta:25 °C	± 1.25%	<b>P</b>
<b>SETUP TIME</b>	3000ms/220VAC max.	I/P:220VAC O/P:full load Ta:25 °C	480ms/220VAC	<b>P</b>
<b>RISE TIME</b>	100ms/220VAC max.	I/P:220VAC O/P:full load Ta:25	32.4ms/220VAC	<b>P</b>
<b>HOLD UP TIME</b>	30ms/220VAC typ.	I/P:220VAC O/P:full load Ta:25	31ms/220VAC	<b>P</b>

**1-3. PROTECTION FUNCTION TEST**

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
<b>SHORT PROTECTION</b>	short every output 1 hour no damage	I/P:240VAC O/P:full load Ta:25 °C	no damage, recovers automatically after fault removed	<b>P</b>
<b>OVER LOAD PROTECTION</b>	110% min.	I/P:220VAC O/P:testing Ta:25 °C	130% recovers automatically after fault removed	<b>P</b>
<b>OVER VOLTAGE PROTECTION</b>	115~140%	I/P:220VAC O/P:min. load Ta:25 °C	130% recovers automatically after fault removed	<b>P</b>
<b>OVER TEMP. PROTECTION</b>	temp. sensor:90±10 °C no damage	I/P:100VAC O/P:full load	O.T.P active, recovers automatically after fault removed	<b>P</b>

**2. SAFETY TEST**

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
-----------	---------------	----------------	--------	---------

<b>WITHSTAND VOLTAGE</b>	I/P-O/P:3KVAC/1min<10mA I/P-F/G:1.5KVAC/1min<10mA O/P-F/G:0.5KVAC/1min<10mA	I/P-O/P:3KVAC/1min I/P-F/G:1.5KVAC/1min O/P-F/G:0.5KVAC/1min Ta:25℃	I/P-O/P:2.8mA I/P-F/G:2.0mA O/P-F/G:2.0mA no damage	<b>P</b>
<b>ISOLATION RESISTANCE</b>	I/O-O/P:500VDC>100MΩ I/O-F/G:500VDC>100MΩ O/P-F/G:500VDC>100MΩ	I/P-O/P:500VDC I/P-F/G:500VDC O/P-F/G:500VDC Ta:25℃	I/P-O/P:∞ I/P-F/G:∞ O/P-F/G:∞ no damage	<b>P</b>

### 3. RELIABILITY TEST

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
<b>LOW TEMP. TURN ON TEST</b>	turn on after 2hour	I/P:220VAC O/P:full load Ta:-40℃	test ok	<b>P</b>
<b>STORAGE TEMP. TEST</b>	no damage	1.thermal shock temp.: -40~+75℃ 2.test time low & high temp.:30min/each 3.total cycle:5cycle 4.input/output condition:static	test ok	<b>P</b>
<b>THERMAL SHOCK TEST</b>	no damage	1.thermal shock temp.: -20~+50℃ 2.test time low & high temp.:30min/each 3.total cycle:10cycle 4.input/output condition: 220VAC 75% load, AC on/off test (turn on 58sec,turn off 2sec)	test ok	<b>P</b>
<b>VIBRATION TEST</b>	no damage	1.CATON&1SET 1.wave form:sine wave 2.frequency:10~500Hz 3.sweep time:10min./sweep cycle 4.acceleration:2G 5.test time:60min. in each(X,Y,Z) 6.Ta:25℃	test ok	<b>P</b>